附:制作要求 100G双胶纸单面黑白打印, 展开尺寸: 210*297mm, 折叠尺寸105*74.25mm 横向压一道竖向压三道,折叠正面朝上。

1. Tools Required









2. Packing List

For Mira-HV25 :




Note: item E is provide separately, not including in battery package. Please contact your dealer if you do not have it.




NO.	Items	NO.	Items
Α	Mounting screw pack	F	Fixing bracket
В	Main negative battery connection cable (0.17m)	G	DC positive output cable (1.2m)
С	Main positive battery connection cable (1.3m)	Н	DC negative output cable (1.2m)
D	Communication cable (BMS-inverter) (1.2m)	- 1	Installation guide
Е	Grounding cable (1m)		

Note: item F is provide separately, not including in battery package. Please contact your dealer if you do not have it.

3. Terminals





4. Installation Steps

Note: Batteries with different color SN label cannot be mixed in one system.

Step 1

Place the front bracket and back bracket as shown below.




Step 2

Insert the battery module into the bracket from front horizontally, and tighten the four screws on the side.



Step 3

Locate the brackets for the second battery on top of the first pair of the bracket and fasten the connecting button on the side.



Step 4


Insert the battery module into the bracket from front horizontally, and tighten the four screws on the side.




Note

Max. 4 pieces battery per stack. Please make sure each system including 1 Mira-BMS.

Battery modules less than 4 pieces:







5. Wiring Steps

Battery power cable:

Step 1: Connect the power cable starting from the first battery module in series with other battery modules (Orange opposite, black negative). A 'click' sound indicates the connections are secured. The positive and negative connection of the battery cable is shown in below.




Step 2 : Measure voltage value: After all battery modules are connected in series, use a multimeter to measure the DC voltage on DC terminal. The total voltage should be N *52±10V (N is the total number of battery module). Please refer to the picture below for voltage test.



Communication cable connection:


Step 1: Take the main positive cable (two orange plugs), the main negative line (two black plugs) to connect the Mira-BMS.

Step 2: Then connect the MODULE on the Mira-BMS to the CAN-1 of the first battery module, connect the CAN-2 of the previous battery module to CAN-1 of the next battery module, leave the last module's CAN-2 vacant. Wiring shall be connected in the sequence as shown in below.



Grounding cable:

Connect the grounding cable to ensure that all batteries are grounded. Wiring shall be connected in the sequence as shown in below.



6. System Start Up

Mira-BMS operation:

- 1. Normal mode: Turn on DC switch first, then press 'POWER' button
- 2. Black start: (No grid connected) press the 'B-start' switch, turn on DC switch, and then press the 'POWER' switch.

Startup steps:

After powering on, all the green lights flash once, and then the running water lights flash once. The light on the Mira-HV25 comes on after a delay, not at the same time as the light on the BMS.



Please scan the QR Code and follow the steps below to download our latest multi-language User Manual/Quick Installation Guide:

Scan the QR Code → Select your Language → Choose to download

User Manual or Quick Installation Guide → Download



10-203-00255-01